

Zone 7 - RFP for Solar Project & Energy Upgrade

Addenda/Clarifications (No. 3)

1. Bonding Requirements

A Bid Bond is not required.

A Payment and Performance Bond will be required for a public work contract.

2. Setback – Corrected Information

City building code requires a 20-foot setback between a building and the canopy of a solar project. As stated in the RFP, all installation and equipment shall comply with applicable building, mechanical, fire, seismic, structural and electrical codes.