

RFQ # 2025-01 - Electrical Power Testing at Mocho Groundwater
Demineralization Plant (MGDP)

QUESTION AND ANSWER

Question	Answer
1. Will the facility provide 480V 350A source for test set?	1. No, the vendor/contractor will need to supply the power source.
2. What is the expected pm schedule for the work? Will everything be scheduled together?	2. Whatever the vendor/contractor requires to get the job completed. We can schedule a shutdown if needed. Zone 7 prefers all work to be scheduled together.
3. Will there be a forklift available onsite to lift a 1500lb test set?	3. No, the vendor/contractor will need to supply their own truck with a liftgate or forklift.